

MINUTES OF PRE-BID MEETING HELD ON THE 9th MAY, 2018 FOR INFRASTRUCTURE FACILITIES, POLLUTION ABATEMENT AND SAFETY SURVEILLANCE FOR NOMINATED BEACHES AT

‘KERALA& KARNATAKA (PACKAGE- II) ’ AND ‘ANDHRA PRADESH & ODISHA (PACKAGE –III)

The pre-bid meeting for following 2 tenders was held on the 9thMay, 2018 at 1130 hrs at the “Indus Conference Hall”, Ministry of Environment, Forest & Climate Change, Jorbagh:

- (i) Infrastructure Facilities, Pollution abatement and safety Surveillance Services for nominated beaches in Kerala & Karnataka
- (ii) Infrastructure Facilities, Pollution abatement and safety Surveillance Services for nominated beaches in Odisha & Andhra Pradesh

The meeting was attended by the representatives of

- 1. M/s Greenovate Pvt Ltd, Kerala
- 2. M/s Eureka Forbes, Mumbai
- 3. M/s BVG India Ltd, Pune
- 4. M/s A 2 Z Infrastructure Ltd, Gurgaon
- 5. M/s Cleantec Infrastructure Pvt. Ltd., Delhi

Name of the Packages/ Ref. No

There are 2 separate packages for “Infrastructure Facilities, Pollution abatement and safety Surveillance for nominated beaches” as detailed below:

- (i) Kerala & Karnataka- NPMU/W/2018-1
- (ii) Andhra Pradesh &Odisha- NPMU/W/2018-2

Name of the officials who participated:

From Purchaser:

- 1. Shri Arvind Nautiyal, APD, SICOM
- 2. Shri Akash Sharma, Controller-F&A, SICOM
- 3. Dr. Shailesh Dodia, Sr. Scientific Officer, SICOM
- 4. Shri Saurabh Sharma, Project Engineer, SICOM
- 5. Shri Sanjai Jalla, Project Management Consultant, SICOM
- 6. Shri Mahesh Rana, Procurement Consultant, SICOM
- 7. Shri Somnath Sen, Procurement Consultant, SICOM

From Prospective Bidders:

1. Shri Bhupendra, Manager, M/s BVG India Ltd.
2. Shri Deepak Mishra, Divisional Head, Eureka Forbes
3. Shri Nitin Lamba, Business Manager, M/s Eureka Forbes
4. Shri J.M. Dsouza, Director, M/s Greenovate Pvt Ltd.
5. Shri Alok Gupta, Executive Director, M/s A 2 Z Infrastructure Ltd.
6. Shri Manoj Chauhan, Vice President, M/s A 2 Z Infrastructure Ltd
7. Md. Iqlak Mohammad, Chief Engineer, M/s A 2 Z Infrastructure Ltd.
8. Shri Abhinav Atre, Sales Co-ordinator, M/s Cleantec Infrastructure Pvt. Ltd.

Opening Remarks

SICOM welcomed the prospective bidders on behalf of the Project and explained the background and context of the bid. Thereafter, the essential points pertaining to the present bids for package-II & III were explained in details and then the meeting was opened for clarifications.

Table No. 1

S. No.	Gist of Query from Bidders	Clarification by SICOM
1	The bidder asked for the eligibility criteria as mentioned on Page 48 regarding facility management services and security services	SICOM clarified that the total value of works related to facility management services and security services (cumulative) executed in last 5 years should not be less than Rs. 10 Crores
2	The qualifying age for Beach Cleaner (ref page 51 of tender) should be 20 years in place of 25 years	SICOM accepted the proposal. Amendment no. 1 dated 16 May 2018 issued
3	The bidder asked for the clarification that the bid price would be inclusive of GST or exclusive of GST.	It was clarified that the bid price should be quoted excluding GST.
4	One of the bidders requested that as minimum wages are likely to be fluctuated, there should be provision for cost escalation where minimum wages are increased	SICOM clarified that budgeting has been done keeping mind the incremental factor in mind and bidders are free to quote their price accordingly.
5	One of the bidder asked for the clarification whether GST registration in Puducherry (ref page 48 of tender) may be done later	SICOM clarified that GST registration for Puducherry may be done after award of contract but before signing the contract.
6	The bidder requested to consider the minimum wages as prevailing in the respective state instead of applying minimum wages of central government	SICOM confirmed that the minimum wages may be paid as applicable in the respective state.
7	One of the bidders pointed out the error in page # 82, 83 & 84 FIN 3.2 (i), (ii) & (iii) respectively w.r.t. Eligibility criteria mentioned in page no. 45 & 47 of tender.	SICOM clarified that it was a typographical error and Amendment No. 1 dated 16 May 2018 issued.
8	One of the bidders asked the clarifications on size of battery bank of solar power plant page 121 including the minimum storage capacity of bank as it was not mentioned clearly in the tender.	SICOM clarified that the specifications mentioned in the tender are for minimum requirements and bidder are advised to configure accordingly suiting total energy storage capacity not less than 240 kWh. Amendment No. 1 dated 16 May 2018 issued.
9	One of the bidders asked for soil data, wind velocity data etc. for estimating the price correctly.	SICOM clarified that bidders are required to visit respective beaches before submitting the quotation/bid for correct estimation of prices/rates.